

Solaris 7 Roadshow PAT results for 2018-2019 Next Due October 2018

<u>No.</u>	<u>Location</u>		<u>Test Date</u>	<u>Appliance ID</u>		<u>Visual Checks</u>		<u>Insulation Class</u>		<u>Earth Bond</u>		<u>Test Load</u>		<u>Leakage</u>		<u>Fuse Check</u>			
1	SITE	S7R	DATE	16/10/2018	APP	SAS001	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
2	SITE	S7R	DATE	16/10/2018	APP	SAS002	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
3	SITE	S7R	DATE	16/10/2018	APP	SAS003	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
4	SITE	S7R	DATE	16/10/2018	APP	SAS004	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
5	SITE	S7R	DATE	16/10/2018	APP	SAS005	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
6	SITE	S7R	DATE	16/10/2018	APP	SAS006	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
7	SITE	S7R	DATE	16/10/2018	APP	SAS007	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
8	SITE	S7R	DATE	16/10/2018	APP	SAS008	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
9	SITE	S7R	DATE	16/10/2018	APP	SAS009	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.79kVA	LEAK	0.0mA	FUSE	PASS
10	SITE	S7R	DATE	16/10/2018	APP	SAS010	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.80kVA	LEAK	0.0mA	FUSE	PASS
11	SITE	S7R	DATE	16/10/2018	APP	SAS011	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.02kVA	LEAK	0.1mA	FUSE	PASS
12	SITE	S7R	DATE	16/10/2018	APP	SAS012	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.03kVA	LEAK	0.1mA	FUSE	PASS
13	SITE	S7R	DATE	16/10/2018	APP	SAS013	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.07kVA	LEAK	0.0mA	FUSE	PASS
14	SITE	S7R	DATE	16/10/2018	APP	SAS014	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.17kVA	LEAK	0.0mA	FUSE	PASS
15	SITE	S7R	DATE	16/10/2018	APP	SAS015	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.41kVA	LEAK	0.2mA	FUSE	PASS
16	SITE	S7R	DATE	16/10/2018	APP	SAS016	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.01kVA	LEAK	0.2mA	FUSE	PASS
17	SITE	S7R	DATE	16/10/2018	APP	SAS017	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.04kVA	LEAK	0.2mA	FUSE	PASS
18	SITE	S7R	DATE	16/10/2018	APP	SAS018	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.09kVA	LEAK	0.1mA	FUSE	PASS
19	SITE	S7R	DATE	16/10/2018	APP	SAS019	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.07kVA	LEAK	0.1mA	FUSE	PASS
20	SITE	S7R	DATE	16/10/2018	APP	SAS020	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
21	SITE	S7R	DATE	16/10/2018	APP	SAS021	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
22	SITE	S7R	DATE	16/10/2018	APP	SAS022	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
23	SITE	S7R	DATE	16/10/2018	APP	SAS023	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
24	SITE	S7R	DATE	16/10/2018	APP	SAS024	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
25	SITE	S7R	DATE	16/10/2018	APP	SAS025	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
26	SITE	S7R	DATE	16/10/2018	APP	SAS026	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.10kVA	LEAK	0.2mA	FUSE	PASS
27	SITE	S7R	DATE	16/10/2018	APP	SAS027	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.09kVA	LEAK	0.0mA	FUSE	PASS
28	SITE	S7R	DATE	16/10/2018	APP	SAS028	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
29	SITE	S7R	DATE	16/10/2018	APP	SAS029	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.66kVA	LEAK	0.2mA	FUSE	PASS
30	SITE	S7R	DATE	16/10/2018	APP	SAS030	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.67kVA	LEAK	0.1mA	FUSE	PASS
31	SITE	S7R	DATE	16/10/2018	APP	SAS031	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.66kVA	LEAK	0.1mA	FUSE	PASS
32	SITE	S7R	DATE	16/10/2018	APP	SAS032	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.65kVA	LEAK	0.2mA	FUSE	PASS
33	SITE	S7R	DATE	16/10/2018	APP	SAS033	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.21kVA	LEAK	0.0mA	FUSE	PASS
34	SITE	S7R	DATE	16/10/2018	APP	SAS034	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.22kVA	LEAK	0.2mA	FUSE	PASS
35	SITE	S7R	DATE	16/10/2018	APP	SAS035	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.22kVA	LEAK	0.1mA	FUSE	PASS
36	SITE	S7R	DATE	16/10/2018	APP	SAS036	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.23kVA	LEAK	0.2mA	FUSE	PASS
37	SITE	S7R	DATE	16/10/2018	APP	SAS037	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.17kVA	LEAK	0.0mA	FUSE	PASS
38	SITE	S7R	DATE	16/10/2018	APP	SAS038	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.41kVA	LEAK	0.0mA	FUSE	PASS
39	SITE	S7R	DATE	16/10/2018	APP	SAS039	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.05kVA	LEAK	0.2mA	FUSE	PASS
40	SITE	S7R	DATE	16/10/2018	APP	SAS040	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.83kVA	LEAK	0.0mA	FUSE	PASS
41	SITE	S7R	DATE	16/10/2018	APP	SAS041	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.81kVA	LEAK	0.1mA	FUSE	PASS
42	SITE	S7R	DATE	16/10/2018	APP	SAS042	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.06kVA	LEAK	0.1mA	FUSE	PASS
43	SITE	S7R	DATE	16/10/2018	APP	SAS043	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.03kVA	LEAK	0.1mA	FUSE	PASS
44	SITE	S7R	DATE	16/10/2018	APP	SAS044	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.02kVA	LEAK	0.0mA	FUSE	PASS
45	SITE	S7R	DATE	16/10/2018	APP	SAS045	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
46	SITE	S7R	DATE	16/10/2018	APP	SAS046	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
47	SITE	S7R	DATE	16/10/2018	APP	SAS047	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
48	SITE	S7R	DATE	16/10/2018	APP	SAS048	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
49	SITE	S7R	DATE	16/10/2018	APP	SAS049	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
50	SITE	S7R	DATE	16/10/2018	APP	SAS050	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS

Solaris 7 Roadshow PAT results for 2018-2019 Next Due October 2018

<u>No.</u>	<u>Location</u>		<u>Test Date</u>	<u>Appliance ID</u>		<u>Visual Checks</u>		<u>Insulation Class</u>		<u>Earth Bond</u>		<u>Test Load</u>		<u>Leakage</u>		<u>Fuse Check</u>			
51	SITE	S7R	DATE	16/10/2018	APP	SAS051	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
52	SITE	S7R	DATE	16/10/2018	APP	SAS052	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
53	SITE	S7R	DATE	16/10/2018	APP	SAS053	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
54	SITE	S7R	DATE	16/10/2018	APP	SAS054	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
55	SITE	S7R	DATE	16/10/2018	APP	SAS055	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
56	SITE	S7R	DATE	16/10/2018	APP	SAS056	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
57	SITE	S7R	DATE	16/10/2018	APP	SAS057	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
58	SITE	S7R	DATE	16/10/2018	APP	SAS058	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.02kVA	LEAK	0.1mA	FUSE	PASS
59	SITE	S7R	DATE	16/10/2018	APP	SAS059	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
60	SITE	S7R	DATE	16/10/2018	APP	SAS060	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
61	SITE	S7R	DATE	16/10/2018	APP	SAS061	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.02kVA	LEAK	0.0mA	FUSE	PASS
62	SITE	S7R	DATE	16/10/2018	APP	SAS062	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.02kVA	LEAK	0.2mA	FUSE	PASS
63	SITE	S7R	DATE	16/10/2018	APP	SAS063	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.00kVA	LEAK	0.2mA	FUSE	PASS
64	SITE	S7R	DATE	16/10/2018	APP	SAS064	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.01kVA	LEAK	0.0mA	FUSE	PASS
65	SITE	S7R	DATE	16/10/2018	APP	SAS065	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.03kVA	LEAK	0.2mA	FUSE	PASS
66	SITE	S7R	DATE	16/10/2018	APP	SAS066	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.02kVA	LEAK	0.2mA	FUSE	PASS
67	SITE	S7R	DATE	16/10/2018	APP	SAS067	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.38kVA	LEAK	0.1mA	FUSE	PASS
68	SITE	S7R	DATE	16/10/2018	APP	SAS068	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.38kVA	LEAK	0.1mA	FUSE	PASS
69	SITE	S7R	DATE	16/10/2018	APP	SAS069	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.37kVA	LEAK	0.1mA	FUSE	PASS
70	SITE	S7R	DATE	16/10/2018	APP	SAS070	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.39kVA	LEAK	0.2mA	FUSE	PASS
71	SITE	S7R	DATE	16/10/2018	APP	SAS071	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.43kVA	LEAK	0.2mA	FUSE	PASS
72	SITE	S7R	DATE	16/10/2018	APP	SAS072	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
73	SITE	S7R	DATE	18/10/2018	APP	SAS073	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
74	SITE	S7R	DATE	18/10/2018	APP	SAS074	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
75	SITE	S7R	DATE	18/10/2018	APP	SAS075	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
76	SITE	S7R	DATE	18/10/2018	APP	SAS076	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
77	SITE	S7R	DATE	18/10/2018	APP	SAS077	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
78	SITE	S7R	DATE	18/10/2018	APP	SAS078	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
79	SITE	S7R	DATE	18/10/2018	APP	SAS079	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
80	SITE	S7R	DATE	18/10/2018	APP	SAS080	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.51kVA	LEAK	0.2mA	FUSE	PASS
81	SITE	S7R	DATE	18/10/2018	APP	SAS081	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.50kVA	LEAK	0.1mA	FUSE	PASS
82	SITE	S7R	DATE	18/10/2018	APP	SAS082	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
83	SITE	S7R	DATE	18/10/2018	APP	SAS083	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
84	SITE	S7R	DATE	18/10/2018	APP	SAS084	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
85	SITE	S7R	DATE	18/10/2018	APP	SAS085	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
86	SITE	S7R	DATE	18/10/2018	APP	SAS086	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.52kVA	LEAK	0.1mA	FUSE	PASS
87	SITE	S7R	DATE	18/10/2018	APP	SAS087	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.47kVA	LEAK	0.0mA	FUSE	PASS
88	SITE	S7R	DATE	18/10/2018	APP	SAS088	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.49kVA	LEAK	0.0mA	FUSE	PASS
89	SITE	S7R	DATE	18/10/2018	APP	SAS089	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.52kVA	LEAK	0.2mA	FUSE	PASS
90	SITE	S7R	DATE	18/10/2018	APP	SAS090	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.51kVA	LEAK	0.2mA	FUSE	PASS
91	SITE	S7R	DATE	18/10/2018	APP	SAS091	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
92	SITE	S7R	DATE	18/10/2018	APP	SAS092	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
93	SITE	S7R	DATE	18/10/2018	APP	SAS093	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
94	SITE	S7R	DATE	18/10/2018	APP	SAS094	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
95	SITE	S7R	DATE	18/10/2018	APP	SAS095	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
96	SITE	S7R	DATE	18/10/2018	APP	SAS096	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
97	SITE	S7R	DATE	18/10/2018	APP	SAS097	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
98	SITE	S7R	DATE	18/10/2018	APP	SAS098	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
99	SITE	S7R	DATE	18/10/2018	APP	SAS099	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
100	SITE	S7R	DATE	18/10/2018	APP	SAS100	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS

Solaris 7 Roadshow PAT results for 2018-2019 Next Due October 2018

<u>No.</u>	<u>Location</u>		<u>Test Date</u>	<u>Appliance ID</u>		<u>Visual Checks</u>		<u>Insulation Class</u>		<u>Earth Bond</u>		<u>Test Load</u>		<u>Leakage</u>		<u>Fuse Check</u>			
151	SITE	S7R	DATE	20/10/2018	APP	SAS151	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.1mA	FUSE	PASS
152	SITE	S7R	DATE	20/10/2018	APP	SAS152	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
153	SITE	S7R	DATE	20/10/2018	APP	SAS153	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
154	SITE	S7R	DATE	20/10/2018	APP	SAS154	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.02kVA	LEAK	0.1mA	FUSE	PASS
155	SITE	S7R	DATE	20/10/2018	APP	SAS155	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
156	SITE	S7R	DATE	20/10/2018	APP	SAS156	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
157	SITE	S7R	DATE	20/10/2018	APP	SAS157	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.02kVA	LEAK	0.0mA	FUSE	PASS
158	SITE	S7R	DATE	20/10/2018	APP	SAS158	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.02kVA	LEAK	0.2mA	FUSE	PASS
159	SITE	S7R	DATE	20/10/2018	APP	SAS159	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.00kVA	LEAK	0.2mA	FUSE	PASS
160	SITE	S7R	DATE	20/10/2018	APP	SAS160	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.01kVA	LEAK	0.0mA	FUSE	PASS
161	SITE	S7R	DATE	20/10/2018	APP	SAS161	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.21kVA	LEAK	0.0mA	FUSE	PASS
162	SITE	S7R	DATE	20/10/2018	APP	SAS162	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.22kVA	LEAK	0.2mA	FUSE	PASS
163	SITE	S7R	DATE	20/10/2018	APP	SAS163	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.22kVA	LEAK	0.1mA	FUSE	PASS
164	SITE	S7R	DATE	20/10/2018	APP	SAS164	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.23kVA	LEAK	0.2mA	FUSE	PASS
165	SITE	S7R	DATE	20/10/2018	APP	SAS165	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.17kVA	LEAK	0.0mA	FUSE	PASS
166	SITE	S7R	DATE	20/10/2018	APP	SAS166	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
167	SITE	S7R	DATE	20/10/2018	APP	SAS167	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
168	SITE	S7R	DATE	20/10/2018	APP	SAS168	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
169	SITE	S7R	DATE	20/10/2018	APP	SAS169	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
170	SITE	S7R	DATE	20/10/2018	APP	SAS170	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.10kVA	LEAK	0.2mA	FUSE	PASS
171	SITE	S7R	DATE	20/10/2018	APP	SAS171	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.09kVA	LEAK	0.0mA	FUSE	PASS
172	SITE	S7R	DATE	20/10/2018	APP	SAS172	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.1mA	FUSE	PASS
173	SITE	S7R	DATE	20/10/2018	APP	SAS173	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
174	SITE	S7R	DATE	20/10/2018	APP	SAS174	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
175	SITE	S7R	DATE	20/10/2018	APP	SAS175	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.02kVA	LEAK	0.1mA	FUSE	PASS
176	SITE	S7R	DATE	20/10/2018	APP	SAS176	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
177	SITE	S7R	DATE	20/10/2018	APP	SAS177	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
178	SITE	S7R	DATE	20/10/2018	APP	SAS178	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.02kVA	LEAK	0.0mA	FUSE	PASS
179	SITE	S7R	DATE	20/10/2018	APP	SAS179	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.43kVA	LEAK	0.1mA	FUSE	PASS
180	SITE	S7R	DATE	20/10/2018	APP	SAS180	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.08R	LOAD	0.02kVA	LEAK	0.0mA	FUSE	PASS
181	SITE	S7R	DATE	20/10/2018	APP	SAS181	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.04kVA	LEAK	0.2mA	FUSE	PASS
182	SITE	S7R	DATE	20/10/2018	APP	SAS182	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.06R	LOAD	0.19kVA	LEAK	0.1mA	FUSE	PASS
183	SITE	S7R	DATE	20/10/2018	APP	SAS183	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
184	SITE	S7R	DATE	20/10/2018	APP	SAS184	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
185	SITE	S7R	DATE	20/10/2018	APP	SAS185	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
186	SITE	S7R	DATE	20/10/2018	APP	SAS186	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
187	SITE	S7R	DATE	20/10/2018	APP	SAS187	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
188	SITE	S7R	DATE	20/10/2018	APP	SAS188	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
189	SITE	S7R	DATE	20/10/2018	APP	SAS189	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
190	SITE	S7R	DATE	20/10/2018	APP	SAS190	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
191	SITE	S7R	DATE	20/10/2018	APP	SAS191	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.73kVA	LEAK	0.2mA	FUSE	PASS
192	SITE	S7R	DATE	20/10/2018	APP	SAS192	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.20kVA	LEAK	0.1mA	FUSE	PASS
193	SITE	S7R	DATE	20/10/2018	APP	SAS193	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.01kVA	LEAK	0.1mA	FUSE	PASS
194	SITE	S7R	DATE	20/10/2018	APP	SAS194	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
195	SITE	S7R	DATE	20/10/2018	APP	SAS195	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.01kVA	LEAK	0.1mA	FUSE	PASS
196	SITE	S7R	DATE	20/10/2018	APP	SAS196	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
197	SITE	S7R	DATE	20/10/2018	APP	SAS197	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.2mA	FUSE	PASS
198	SITE	S7R	DATE	20/10/2018	APP	SAS198	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
199	SITE	S7R	DATE	20/10/2018	APP	SAS199	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
200	SITE	S7R	DATE	20/10/2018	APP	SAS200	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS

Solaris 7 Roadshow PAT results for 2018-2019 Next Due October 2018

<u>No.</u>	<u>Location</u>		<u>Test Date</u>	<u>Appliance ID</u>		<u>Visual Checks</u>			<u>Insulation Class</u>		<u>Earth Bond</u>		<u>Test Load</u>		<u>Leakage</u>		<u>Fuse Check</u>		
251	SITE	S7R	DATE	21/10/2018	APP	SAS251	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
252	SITE	S7R	DATE	21/10/2018	APP	SAS252	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.02kVA	LEAK	0.2mA	FUSE	PASS
253	SITE	S7R	DATE	21/10/2018	APP	SAS253	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	1.00kVA	LEAK	0.2mA	FUSE	PASS
254	SITE	S7R	DATE	21/10/2018	APP	SAS254	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	1.01kVA	LEAK	0.0mA	FUSE	PASS
255	SITE	S7R	DATE	21/10/2018	APP	SAS255	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	1.03kVA	LEAK	0.2mA	FUSE	PASS
256	SITE	S7R	DATE	21/10/2018	APP	SAS256	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
257	SITE	S7R	DATE	21/10/2018	APP	SAS257	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.1mA	FUSE	PASS
258	SITE	S7R	DATE	21/10/2018	APP	SAS258	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.07R	LOAD	0.01kVA	LEAK	0.2mA	FUSE	PASS
259	SITE	S7R	DATE	21/10/2018	APP	SAS259	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.10kVA	LEAK	0.2mA	FUSE	PASS
260	SITE	S7R	DATE	21/10/2018	APP	SAS260	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
261	SITE	S7R	DATE	21/10/2018	APP	SAS261	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
262	SITE	S7R	DATE	21/10/2018	APP	SAS262	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.01kVA	LEAK	0.1mA	FUSE	PASS
263	SITE	S7R	DATE	21/10/2018	APP	SAS263	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.02kVA	LEAK	0.2mA	FUSE	PASS
264	SITE	S7R	DATE	21/10/2018	APP	SAS264	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
265	SITE	S7R	DATE	21/10/2018	APP	SAS265	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
266	SITE	S7R	DATE	23/10/2018	APP	SAS266	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.19kVA	LEAK	0.0mA	FUSE	PASS
267	SITE	S7R	DATE	23/10/2018	APP	SAS267	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.19kVA	LEAK	0.0mA	FUSE	PASS
268	SITE	S7R	DATE	23/10/2018	APP	SAS268	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.19kVA	LEAK	0.0mA	FUSE	PASS
269	SITE	S7R	DATE	23/10/2018	APP	SAS269	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
270	SITE	S7R	DATE	23/10/2018	APP	SAS270	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
271	SITE	S7R	DATE	23/10/2018	APP	SAS271	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.09R	LOAD	0.13kVA	LEAK	0.0mA	FUSE	PASS
272	SITE	S7R	DATE	23/10/2018	APP	SAS272	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.10R	LOAD	0.14kVA	LEAK	0.1mA	FUSE	PASS
273	SITE	S7R	DATE	23/10/2018	APP	SAS273	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS
274	SITE	S7R	DATE	23/10/2018	APP	SAS274	AUTO	VISUAL	PASS	INSU I	>300.0MR	EARTH	0.08R	LOAD	0.05kVA	LEAK	0.0mA	FUSE	PASS
275	SITE	S7R	DATE	23/10/2018	APP	SAS275	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.01kVA	LEAK	0.0mA	FUSE	PASS
276	SITE	S7R	DATE	23/10/2018	APP	SAS276	AUTO	VISUAL	PASS	INSU II	>300.0MR	EARTH	N/A	LOAD	0.00kVA	LEAK	0.0mA	FUSE	PASS